


The two black leads marked 'Ground' are connected together inside the DIM14HP. Please note the 0-10V control input is not isolated from the supply.



DIM14HP Ground connection should be tee'd off the high current ground.